


### Topics for Today:

- Course Info:
  - Web page: <https://pages.mtu.edu/~bamork/ee5220/>
  - Software - Matlab. ATP/EMTP [ License - [www.emtp.org](http://www.emtp.org) ] ATP tutorials posted on our course web page
  - [EE5220-L@mtu.edu](mailto:EE5220-L@mtu.edu) (participation = min half letter grade, 5%)
- HW#7 - due Tues March 13<sup>th</sup> 9am
- Term Project Week 8: (by Monday following) - complete reference list and fully-detailed table of contents, via e-mail to grader.
- Use of ATPDraw's Line Constants to obtain parameters, build line models.
  - Conductor Sag, NESC guidelines for minimum clearance
  - Weather-affected changes in parameters
- Use of Line Constants .lis output file to obtain detailed matrices, line parameters, propagation constants.
  - Obtaining the .lis file
  - Interpreting the matrices: Phase matrices; Sequence matrices
- Long-Line approximations, performance as fraction of wavelength
- Basics for lines vs. cables; traveling wave model (See Feb 19<sup>th</sup> video/ATP)

ATP Point of the Day: Enable all error/warning/caution messages for auto-display!!





# ATP Pointers

- Float Subnetwork - next page
- Auto-Detect Sim Errors
  - Turn on!

ATP > Output >  Auto Detect

⏏  
⏏  
⏏  
⏏  
⏏  
⏏  
⋮



is singular  
 $\div 0 \Rightarrow$  crash!

$y_{33} = + \Sigma$  branches landing on Node 3.

$= + G_{34}$

$y_{34} = - \Sigma$  spanning admittances

$= - G_{34}$

In a given row,  $\Sigma y_i = 0$  if no ground connection.



Row 3:

0	0	$+G_{34}$	$-G_{34}$
$y_{31}$	$y_{32}$	$y_{33}$	$y_{34}$

This implies singularity.

Line Charging Example: LCC\_3b.alc (Coupled-PI, 60 Hz model).

Simulation file: Line\_Chg.acp



As predicted, phase B line current is larger than A or C, due to larger capacitive coupling to phase B. Larger capacitive effect  $\Rightarrow$  smaller input impedance  $\Rightarrow$  higher current...

See Line Constants output log file, LCC\_3b.lis, on following pages. Be sure to print these with fixed-pitch font so that columnar data is aligned. This file is created in atp\atpdraw\atp\ folder when you "build" the line model (from within Line Constants parameter/dialog box, click on Run ATP).

- 17 cards of disk file read into card cache cells 1 onward.

Alternative Transients Program (ATP), Watcom translation. All rights reserved by Can/Am user group of Portland, Oregon, USA.

Date (dd-mth-yy) and time of day (hh.mm.ss) = 29-Feb-08 15.24.27 Name of disk plot file is LCC\_3B.pl4

Consult the 860-page ATP Rule Book of the Can/Am EMTF User Group in Portland, Oregon, USA. Source code date is 22 January 2002.

Total size of LABCOM tables = 7546726 INTEGER words. VARDIM List Sizes follow : 6002 10K 192K 900 320K 1200

15K 120K 2250 3800 720 1200 72800 510 90K 800 90 254 120K 100K 3K 15K 192K 30 30K 160K 600 210K 300 60

```
-----+-----
Descriptive interpretation of input data cards. | Input data card images are shown below, all 80 columns, character by character
                                                | 0           1           2           3           4           5           6           7           8
                                                | 012345678901234567890123456789012345678901234567890123456789012345678901234567890
-----+-----
```

```
-----+-----
Comment card.   KOMPAR > 0.                | C data:LCC_3B.ATP
Marker card preceding new EMTF data case.   | BEGIN NEW DATA CASE
Compute overhead line constants. Limit = 120 | LINE CONSTANTS
Erase all of 0 cards in the punch buffer.   | $ERASE
New XOPT, COPT = 6.00000000E+01 6.00000000E+01 | $UNITS, 60., 60.
Pairs of 6-character bus names for each phase. | BRANCH IN__AOUT__AIN__BOUT__BIN__COUT__C
Request for metric (not English) units.     | METRIC
Line conductor card. 3.330E-01 1.042E-01 4 | 10.333 0.10418 4 1.197 1. 55. 35. 18. 0.0 2
Line conductor card. 3.330E-01 1.042E-01 4 | 20.333 0.10418 4 1.197 28. 60.8 40.8 18. 0.0 2
Line conductor card. 3.330E-01 1.042E-01 4 | 30.333 0.10418 4 1.197 55. 55. 35. 18. 0.0 2
Line conductor card. 5.000E-01 2.400E+00 4 | 0 0.5 2.4 4 0.385 15. 81. 61. 0.0 0.0 0
Line conductor card. 5.000E-01 2.400E+00 4 | 0 0.5 2.4 4 0.385 42. 81. 61. 0.0 0.0 0
Blank card terminating conductor cards.     | BLANK CARD ENDING CONDUCTOR CARDS
Frequency card. 1.000E+02 6.000E+01 2.030E+01 | 100. 60. 111111 111111 0 20.3 44
-----+-----
```

Line conductor table after sorting and initial processing.

Table Row	Phase Number	Skin effect R-type	Resistance R (ohm/km)	Reactance data specification X-type	X(ohm/km) or GMR	Diameter ( cm )	Horizontal X (mtrs)	Avg height Y (mtrs)	Name
1	1	.33300	.10418	4	.000000	1.19700	0.910	41.667	
2	2	.33300	.10418	4	.000000	1.19700	27.910	47.467	
3	3	.33300	.10418	4	.000000	1.19700	54.910	41.667	
4	1	.33300	.10418	4	.000000	1.19700	1.090	41.667	
5	2	.33300	.10418	4	.000000	1.19700	28.090	47.467	
6	3	.33300	.10418	4	.000000	1.19700	55.090	41.667	
7	0	.50000	2.40000	4	.000000	.38500	15.000	67.667	
8	0	.50000	2.40000	4	.000000	.38500	42.000	67.667	

Matrices are for earth resistivity = 1.00000000E+02 ohm-meters and frequency 6.00000000E+01 Hz. Correction factor = 1.00000000E-06

Inverted susceptance matrix, in units of [ohm-kmeter ] for the system of physical conductors.  
Rows and columns proceed in the same order as the sorted input.

```
1  4.549349E+05
2  5.796193E+04  4.611489E+05
3  2.904493E+04  5.796193E+04  4.549349E+05
4  2.926453E+05  5.824006E+04  2.915716E+04  4.549349E+05
5  5.768579E+04  2.988593E+05  5.824006E+04  5.796193E+04  4.611489E+05
6  2.893329E+04  5.768579E+04  2.926453E+05  2.904493E+04  5.796193E+04  4.549349E+05
7  6.273758E+04  7.511599E+04  4.259954E+04  6.286548E+04  7.493095E+04  4.247403E+04  5.321400E+05
8  4.178340E+04  7.388622E+04  6.355973E+04  4.190689E+04  7.407620E+04  6.343690E+04  7.778668E+04  5.321400E+05
```

Susceptance matrix, in units of [mhos/kmeter ] for the system of physical conductors.  
Rows and columns proceed in the same order as the sorted input.

```
1  3.778608E-06
2  -8.368508E-08  3.792707E-06
3  -2.884376E-08  -8.317809E-08  3.779960E-06
4  -2.382750E-06  -8.581586E-08  -2.938220E-08  3.779552E-06
5  -8.131578E-08  -2.369129E-06  -8.562109E-08  -8.336752E-08  3.792707E-06
6  -2.831840E-08  -8.112390E-08  -2.382342E-06  -2.884193E-08  -8.348782E-08  3.779018E-06
7  -1.272917E-07  -1.478392E-07  -6.273436E-08  -1.281108E-07  -1.455386E-07  -6.203392E-08  1.992176E-06
8  -6.068211E-08  -1.422685E-07  -1.302669E-07  -6.135833E-08  -1.446100E-07  -1.295006E-07  -2.154518E-07  1.991177E-06
```

Inverted susceptance matrix, in units of [ohm-kmeter ] for the system of equivalent phase conductors.  
Rows and columns proceed in the same order as the sorted input.

```
1 3.643293E+05
2 4.515578E+04 3.618017E+05
3 2.043237E+04 4.503427E+04 3.640893E+05
```

Inverted susceptance matrix, in units of [ohm-kmeter ] for symmetrical components of the equivalent phase conductor  
Rows proceed in the sequence (0, 1, 2), (0, 1, 2), etc.; columns proceed in the sequence (0, 2, 1), (0, 2, 1), etc.

```
0 4.371550E+05
  0.000000E+00
1 -3.618781E+03 8.621409E+03
  6.476654E+03 1.493445E+04
2 -3.618781E+03 3.265326E+05 8.621409E+03
  -6.476654E+03 0.000000E+00 -1.493445E+04
```

Susceptance matrix, in units of [mhos/kmeter ] for the system of equivalent phase conductors.  
Rows and columns proceed in the same order as the sorted input.

```
1 2.792660E-06
2 -3.341842E-07 2.847155E-06
3 -1.153863E-07 -3.334109E-07 2.794294E-06
```

Susceptance matrix, in units of [mhos/kmeter ] for symmetrical components of the equivalent phase conductor  
Rows proceed in the sequence (0, 1, 2), (0, 1, 2), etc.; columns proceed in the sequence (0, 2, 1), (0, 2, 1), etc.

```
0 2.289382E-06
  0.000000E+00
1 2.685381E-08 -8.177182E-08
  -4.790199E-08 -1.415826E-07
2 2.685381E-08 3.072363E-06 -8.177182E-08
  4.790199E-08 2.193008E-23 1.415826E-07
```



Impedance matrix, in units of [ohms/kmeter ] for the system of physical conductors.  
Rows and columns proceed in the same order as the sorted input.

```
1  1.585799E-01
   9.161533E-01

2  5.335205E-02  1.579204E-01
   2.650855E-01  9.169840E-01

3  5.351994E-02  5.335205E-02  1.585799E-01
   2.141735E-01  2.650855E-01  9.161533E-01

4  5.373760E-02  5.335275E-02  5.352137E-02  1.585799E-01
   6.441420E-01  2.655672E-01  2.144247E-01  9.161533E-01

5  5.335134E-02  5.307805E-02  5.335275E-02  5.335205E-02  1.579204E-01
   2.646068E-01  6.449727E-01  2.655672E-01  2.650855E-01  9.169840E-01

6  5.351852E-02  5.335134E-02  5.373760E-02  5.351994E-02  5.335205E-02  1.585799E-01
   2.139232E-01  2.646068E-01  6.441420E-01  2.141735E-01  2.650855E-01  9.161533E-01

7  5.227275E-02  5.196386E-02  5.218193E-02  5.227308E-02  5.196356E-02  5.218100E-02  2.450972E+00
   2.613432E-01  2.775767E-01  2.254437E-01  2.615609E-01  2.772711E-01  2.252056E-01  1.008814E+00

8  5.217575E-02  5.196183E-02  5.227484E-02  5.217670E-02  5.196215E-02  5.227453E-02  5.088096E-02  2.450972E+00
   2.238908E-01  2.755436E-01  2.627413E-01  2.241264E-01  2.758580E-01  2.625327E-01  2.700313E-01  1.008814E+00
```

Inverted impedance matrix, in units of [mho-kmeter ] for the system of physical conductors.  
Rows and columns proceed in the same order as the sorted input.

```
1  6.635409E-01
   -1.972531E+00

2  -2.034846E-04  6.691177E-01
   1.006290E-01  -1.990403E+00

3  5.814223E-03  9.537902E-06  6.641024E-01
   6.540311E-02  1.002743E-01  -1.973428E+00

4  -5.699559E-01  -7.072962E-04  5.683619E-03  6.639485E-01
   1.227857E+00  1.016166E-01  6.566408E-02  -1.973374E+00

5  4.147604E-04  -5.645847E-01  -6.318118E-04  -6.409805E-05  6.691187E-01
   9.934170E-02  1.210408E+00  1.015886E-01  1.003022E-01  -1.990404E+00
```

```

6  5.941020E-03  4.892146E-04 -5.698013E-01  5.814883E-03 -1.271745E-04  6.636963E-01
   6.514757E-02  9.931377E-02  1.227803E+00  6.540305E-02  1.006009E-01 -1.972585E+00

7  -3.826235E-02 -4.103578E-02 -2.594205E-02 -3.835165E-02 -4.066019E-02 -2.584631E-02  3.678260E-01
   1.611574E-02  1.707574E-02  1.353646E-02  1.611066E-02  1.709846E-02  1.353963E-02 -1.295084E-01

8  -2.556308E-02 -4.013470E-02 -3.886552E-02 -2.565606E-02 -4.051901E-02 -3.878624E-02 -1.298829E-02  3.677574E-01
   1.345330E-02  1.701024E-02  1.626901E-02  1.345057E-02  1.698801E-02  1.627394E-02 -1.273678E-02 -1.295857E-01

```

Impedance matrix, in units of [ohms/kmeter ] for the system of equivalent phase conductors.  
Rows and columns proceed in the same order as the sorted input.

```

1  1.338254E-01
   7.457905E-01

2  8.542610E-02  1.429545E-01
   2.270646E-01  7.388557E-01

3  8.082529E-02  8.559932E-02  1.341662E-01
   1.798439E-01  2.269184E-01  7.455102E-01
   Both "R" and "X" are in [ohms]; "C" are in [microMhos].

```

Impedance matrix, in units of [ohms/kmeter ] for symmetrical components of the equivalent phase conductor  
Rows proceed in the sequence (0, 1, 2), (0, 1, 2), etc.; columns proceed in the sequence (0, 2, 1), (0, 2, 1), etc.

```

0  3.048825E-01
   1.165937E+00

1  -1.411331E-02 -2.911309E-02
   -2.753773E-03  1.696461E-02

2  9.307584E-03  5.303180E-02  2.925462E-02
   -1.048399E-02  5.321098E-01  1.672600E-02

```

Sequence	Surge impedance		Attenuation	velocity	Wavelength	Resistance	Reactance	Susceptance
	magnitude(ohm)	angle(degr.)	db/km	km/sec	km	ohm/km	ohm/km	mho/km
Zero :	7.25537E+02	-7.32712E+00	1.84000E-03	2.28831E+05	3.81384E+03	3.04883E-01	1.16594E+00	2.28938E-06
Positive:	4.17193E+02	-2.84574E+00	5.52738E-04	2.94481E+05	4.90801E+03	5.30318E-02	5.32110E-01	3.07236E-06

Inverted impedance matrix, in units of [mho-kmeter] for the system of equivalent phase conductors.  
 Rows and columns proceed in the same order as the sorted input.

```

1  1.875775E-01
   -1.490192E+00

2  -5.601184E-04  2.090670E-01
   4.018895E-01 -1.559992E+00

3  2.325374E-02 -2.602338E-04  1.881962E-01
   2.616178E-01  4.017776E-01 -1.490408E+00

```

Inverted impedance matrix, in units of [mho-kmeter] for symmetrical components of the equivalent phase conductor  
 Rows proceed in the sequence (0, 1, 2), (0, 1, 2), etc.; columns proceed in the sequence (0, 2, 1), (0, 2, 1), etc.

```

0  2.099025E-01
   -8.033406E-01

1  -2.022159E-02 -1.124957E-01
   -1.252160E-02  3.857806E-02

2  2.059020E-02  1.874691E-01  8.965024E-02
   -1.082245E-02 -1.868626E+00  7.812573E-02

```

Request for flushing of punch buffer. |\$PUNCH

A listing of 80-column card images now being flushed from punch buffer follows.

```

=====
123456789012345678901234567890123456789012345678901234567890123456789
=====
C <++++++> Cards punched by support routine on 29-Feb-08 15.24.27 <++++++>
C LINE CONSTANTS
C $ERASE
C $UNITS, 60., 60.
C BRANCH IN__AOUT__AIN__BOUT__BIN__COUT__C
C METRIC
C 10.333 0.10418 4 1.197 1. 55. 35. 18. 0.0
C 20.333 0.10418 4 1.197 28. 60.8 40.8 18. 0.0
C 30.333 0.10418 4 1.197 55. 55. 35. 18. 0.0
C 0 0.5 2.4 4 0.385 15. 81. 61. 0.0 0.0

```

C 0 0.5 2.4 4 0.385 42. 81. 61. 0.0 0.0

C BLANK CARD ENDING CONDUCTOR CARDS

C 100. 60. 111111 111111 0 20.3 44

\$VINTAGE, 1

1IN\_\_AOUT\_\_A 2.71665557E+00 1.51395469E+01 5.66909987E+01

2IN\_\_BOUT\_\_B 1.73414980E+00 4.60941126E+00 -6.78394003E+00

2.90197664E+00 1.49987705E+01 5.77972369E+01

3IN\_\_COUT\_\_C 1.64075348E+00 3.65083164E+00 -2.34234185E+00

1.73766625E+00 4.60644445E+00 -6.76824125E+00

2.72357373E+00 1.51338568E+01 5.67241673E+01

\$VINTAGE, -1,

=====< End of LUNIT7 punched cards as flushed by \$PUNCH request >=====

Blank card terminating frequency cards.

|BLANK CARD ENDING FREQUENCY CARDS

Blank card ending "LINE CONSTANTS" cases.


|BLANK CARD ENDING LINE CONSTANT

Total case timing (CP, I/O, tot), sec: 0.656 0.000 0.656


# Weather Effects

- Rain, run-off, pooling

- Operating Temp:  $-40^{\circ}\text{F} \rightarrow 180^{\circ}\text{F}$



$\rho$  (0.0012) - is not constant  
- varies seasonally or  
w/ precipitation



## NESE

- Clearances
- Open field
- Roads / ARE
- Bldgs.

$C_{gd}$ : decrease  $w$ /height  $\left[ C \propto \ln \frac{r}{D} \right]$

$\Rightarrow$  Lucky to get within 5-10%  
of actual line parameters.